



QUALITY ASSURANCE PROJECT PLAN
HIGH BRIDGE SCHOOL DISTRICT
NOVEMBER 2021

PARS
ENVIRONMENTAL

Results-High Bridge Elementary School-Initial

| Field ID | Flushed (Y/N) | Lab. Sample ID | Lab. Name | Lab. ID | Date Sampled | Time Sampled | Analytical Method | Date of Analysis | Time of Analysis | Conc. (ug/L) | Rpt. Limit (ug/L) | DF | Digested (Y/N) | Qfr. |
|-------------------|---------------|----------------|-----------|-------------|--------------|--------------|-------------------|------------------|------------------|--------------|-------------------|-----|----------------|------|
| HES - Field Blank | N | P21-12155-01 | PAS | NIDEP 15001 | 11/4/2021 | 7:40 | SM 3113 B | 11/5/2021 | 14:44 | -0.09 | 2.00 | 1 | N | ND |
| HES-01-201-SB-P | N | P21-12155-02 | PAS | NIDEP 15001 | 11/4/2021 | 7:41 | SM 3113 B | 11/5/2021 | 15:04 | 25.7 | 8.00 | 4 | N | |
| HES-01-203-SB-P | N | P21-12155-03 | PAS | NIDEP 15001 | 11/4/2021 | 7:42 | SM 3113 B | 11/8/2021 | 10:51 | 59.7 | 10.0 | 5 | N | |
| HES-01-205-SB-P | N | P21-12155-04 | PAS | NIDEP 15001 | 11/4/2021 | 7:43 | SM 3113 B | 11/8/2021 | 10:55 | 97.8 | 20.0 | 10 | N | |
| HES-01-207-SB-P | N | P21-12155-05 | PAS | NIDEP 15001 | 11/4/2021 | 7:45 | SM 3113 B | 11/8/2021 | 10:59 | 78.7 | 20.0 | 10 | N | |
| HES-01-209-SB-P | N | P21-12155-06 | PAS | NIDEP 15001 | 11/4/2021 | 7:47 | SM 3113 B | 11/5/2021 | 15:29 | 14.9 | 2.00 | 1 | N | |
| HES-01-H-211-DW-P | N | P21-12155-07 | PAS | NIDEP 15001 | 11/4/2021 | 7:48 | SM 3113 B | 11/8/2021 | 11:11 | 595 | 200 | 100 | N | |
| HES-01-212-SB-P | N | P21-12155-08 | PAS | NIDEP 15001 | 11/4/2021 | 7:49 | SM 3113 B | 11/8/2021 | 11:15 | 27.7 | 4.00 | 2 | N | |
| HES-01-H301-DW-P | N | P21-12155-09 | PAS | NIDEP 15001 | 11/4/2021 | 7:50 | SM 3113 B | 11/5/2021 | 15:59 | -0.09 | 2.00 | 1 | N | ND |
| HES-01-301-SB-P | N | P21-12155-10 | PAS | NIDEP 15001 | 11/4/2021 | 7:52 | SM 3113 B | 11/5/2021 | 16:03 | 0.570 | 2.00 | 1 | N | ND |
| HES-01-302-SB-P | N | P21-12155-11 | PAS | NIDEP 15001 | 11/4/2021 | 7:54 | SM 3113 B | 11/8/2021 | 11:19 | 24.8 | 4.00 | 2 | N | |
| HES-01-304-SB-P | N | P21-12155-12 | PAS | NIDEP 15001 | 11/4/2021 | 7:56 | SM 3113 B | 11/5/2021 | 16:10 | 7.74 | 2.00 | 1 | N | |
| HES-01-306-SB-P | N | P21-12155-13 | PAS | NIDEP 15001 | 11/4/2021 | 7:58 | SM 3113 B | 11/5/2021 | 16:14 | 3.88 | 2.00 | 1 | N | |
| HES-01-H304-WC1-P | N | P21-12155-14 | PAS | NIDEP 15001 | 11/4/2021 | 8:00 | SM 3113 B | 11/5/2021 | 16:18 | -0.30 | 2.00 | 1 | N | ND |
| HES-01-H304-WC3-P | N | P21-12155-15 | PAS | NIDEP 15001 | 11/4/2021 | 8:02 | SM 3113 B | 11/5/2021 | 16:21 | 2.74 | 2.00 | 1 | N | |



QUALITY ASSURANCE PROJECT PLAN
HIGH BRIDGE SCHOOL DISTRICT
NOVEMBER 2021



| Field ID | Flushed (Y/N) | Lab. Sample ID | Lab. Name | Lab. ID | Date Sampled | Time Sampled | Analytical Method | Date of Analysis | Time of Analysis | Conc. (ug/L) | Rpt. Limit (ug/L) | DF | Digested (Y/N) | Qtr. |
|-------------------|---------------|----------------|-----------|-------------|--------------|--------------|-------------------|------------------|------------------|--------------|-------------------|----|----------------|------|
| HES-01-303-SB-P | N | P21-12155-16 | PAS | NIDEP 15001 | 11/4/2021 | 8:03 | SM 3113 B | 11/5/2021 | 16:25 | 2.96 | 2.00 | 1 | N | |
| HES-01-305-SB-P | N | P21-12155-17 | PAS | NIDEP 15001 | 11/4/2021 | 8:04 | SM 3113 B | 11/5/2021 | 16:36 | 2.74 | 2.00 | 1 | N | |
| HES-01-308-SB-P | N | P21-12155-18 | PAS | NIDEP 15001 | 11/4/2021 | 8:05 | SM 3113 B | 11/5/2021 | 16:40 | 1.43 | 2.00 | 1 | N | J |
| HES-01-KIT-FP1-P | N | P21-12155-19 | PAS | NIDEP 15001 | 11/4/2021 | 8:08 | SM 3113 B | 11/8/2021 | 11:23 | 22.4 | 4.00 | 2 | N | |
| HES-01-KIT-FP2-P | N | P21-12155-20 | PAS | NIDEP 15001 | 11/4/2021 | 8:10 | SM 3113 B | 11/5/2021 | 16:48 | 2.09 | 2.00 | 1 | N | |
| HES-01-KIT-FP3-P | N | P21-12155-21 | PAS | NIDEP 15001 | 11/4/2021 | 8:12 | SM 3113 B | 11/8/2021 | 11:27 | 85.9 | 20.0 | 10 | N | |
| HES-01-KIT-FP4-P | N | P21-12155-22 | PAS | NIDEP 15001 | 11/4/2021 | 8:14 | SM 3113 B | 11/5/2021 | 14:55 | 13.5 | 2.00 | 1 | N | |
| HES-01-KIT-FP5-P | N | P21-12155-23 | PAS | NIDEP 15001 | 11/4/2021 | 8:16 | SM 3113 B | 11/8/2021 | 11:43 | 190 | 100 | 50 | N | |
| HES-01-KIT-FP6-P | N | P21-12155-24 | PAS | NIDEP 15001 | 11/4/2021 | 8:20 | SM 3113 B | 11/5/2021 | 15:03 | 8.96 | 2.00 | 1 | N | |
| HES-01-KIT-KT-P | N | P21-12155-25 | PAS | NIDEP 15001 | 11/4/2021 | 8:22 | SM 3113 B | 11/8/2021 | 13:26 | 238 | 100 | 50 | N | |
| HES-02-101-SB1-P | N | P21-12155-26 | PAS | NIDEP 15001 | 11/4/2021 | 8:24 | SM 3113 B | 11/8/2021 | 13:30 | 19.6 | 4.00 | 2 | N | |
| HES-02-101-SB2-P | N | P21-12155-27 | PAS | NIDEP 15001 | 11/4/2021 | 8:25 | SM 3113 B | 11/8/2021 | 13:35 | 19.6 | 4.00 | 2 | N | |
| HES-02-H-101-DW-P | N | P21-12155-28 | PAS | NIDEP 15001 | 11/4/2021 | 8:28 | SM 3113 B | 11/5/2021 | 15:35 | -0.38 | 2.00 | 1 | N | ND |
| HES-02-401-NS1-P | N | P21-12155-29 | PAS | NIDEP 15001 | 11/4/2021 | 8:29 | SM 3113 B | 11/5/2021 | 15:39 | 9.87 | 2.00 | 1 | N | |
| HES-02-401-NS2-P | N | P21-12155-30 | PAS | NIDEP 15001 | 11/4/2021 | 8:30 | SM 3113 B | 11/5/2021 | 15:43 | 15.1 | 2.00 | 1 | N | |
| HES-02-401-NS3-P | N | P21-12155-31 | PAS | NIDEP 15001 | 11/4/2021 | 8:32 | SM 3113 B | 11/5/2021 | 15:48 | 13.7 | 2.00 | 1 | N | |
| HES-02-405-FC-P | N | P21-12155-32 | PAS | NIDEP 15001 | 11/4/2021 | 8:34 | SM 3113 B | 11/5/2021 | 15:52 | 4.86 | 2.00 | 1 | Y | |



QUALITY ASSURANCE PROJECT PLAN
HIGH BRIDGE SCHOOL DISTRICT
NOVEMBER 2021



| Field ID | Flushed (Y/N) | Lab. Sample ID | Lab. Name | Lab. ID | Date Sampled | Time Sampled | Analytical Method | Date of Analysis | Time of Analysis | Conc. (ug/L) | Rpt. Limit (ug/L) | DF | Digested (Y/N) | Qfr. |
|-------------------|---------------|----------------|-----------|-------------|--------------|--------------|-------------------|------------------|------------------|--------------|-------------------|-----|----------------|------|
| HES-02-H105-DW1-P | N | P21-12155-33 | PAS | NIDEP 15001 | 11/4/2021 | 8:35 | SM 3113 B | 11/8/2021 | 13:39 | 1510 | 200 | 100 | N | |
| HES-02-H105-DW2-P | N | P21-12155-34 | PAS | NIDEP 15001 | 11/4/2021 | 8:36 | SM 3113 B | 11/8/2021 | 13:55 | 691 | 200 | 100 | N | |
| HES-02-102-SB-P | N | P21-12155-35 | PAS | NIDEP 15001 | 11/4/2021 | 8:38 | SM 3113 B | 11/8/2021 | 13:59 | 119 | 20.0 | 10 | N | |
| HES-02-105-SB-P | N | P21-12155-36 | PAS | NIDEP 15001 | 11/4/2021 | 8:39 | SM 3113 B | 11/8/2021 | 14:12 | 523 | 200 | 100 | N | |
| HES-02-107-SB-P | N | P21-12155-37 | PAS | NIDEP 15001 | 11/4/2021 | 8:40 | SM 3113 B | 11/8/2021 | 14:16 | 274 | 100 | 50 | N | |
| HES-02-104-SB-P | N | P21-12155-38 | PAS | NIDEP 15001 | 11/4/2021 | 8:42 | SM 3113 B | 11/8/2021 | 14:20 | 262 | 100 | 50 | N | |
| HES-02-H109-DW-P | N | P21-12155-39 | PAS | NIDEP 15001 | 11/4/2021 | 8:44 | SM 3113 B | 11/8/2021 | 14:24 | 35.8 | 6.00 | 3 | N | |
| HES-02-109-SB-P | N | P21-12155-40 | PAS | NIDEP 15001 | 11/4/2021 | 8:46 | SM 3113 B | 11/8/2021 | 14:28 | 346 | 100 | 50 | N | |
| HES-02-106-SB-P | N | P21-12155-41 | PAS | NIDEP 15001 | 11/4/2021 | 8:47 | SM 3113 B | 11/8/2021 | 14:32 | 214 | 100 | 50 | N | |
| HES-02-H112-DW-P | N | P21-12155-42 | PAS | NIDEP 15001 | 11/4/2021 | 8:48 | SM 3113 B | 11/5/2021 | 16:58 | 1.44 | 2.00 | 1 | N | J |
| HES-02-112-SB-P | N | P21-12155-43 | PAS | NIDEP 15001 | 11/4/2021 | 8:49 | SM 3113 B | 11/5/2021 | 17:02 | 11.9 | 2.00 | 1 | N | |
| HES-02-113-SB-P | N | P21-12155-44 | PAS | NIDEP 15001 | 11/4/2021 | 8:50 | SM 3113 B | 11/5/2021 | 17:06 | 5.54 | 2.00 | 1 | N | |
| HES-02-114-SB-P | N | P21-12155-45 | PAS | NIDEP 15001 | 11/4/2021 | 8:51 | SM 3113 B | 11/5/2021 | 17:10 | 14.7 | 2.00 | 1 | N | |



QUALITY ASSURANCE PROJECT PLAN
HIGH BRIDGE SCHOOL DISTRICT
NOVEMBER 2021



PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result * Federal Action Level

Exceeds EPA Action Limit (> 15.5ppb)

Blg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)primary / (F)lush

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT = Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT = Bottle Filler
- HB = Hose Bib