



QUALITY ASSURANCE PROJECT PLAN  
HIGH BRIDGE SCHOOL DISTRICT  
NOVEMBER 2021



**Results-High Bridge Middle School-Initial**

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
HMS - Field Blank	N	P21-12151-01	PAS	NJDEP 15001	11/4/2021	7:00	SM 3113 B	11/5/2021	11:41	-0.74	2.00	1	N	ND
HMS-01-HGYM-WC-P	N	P21-12151-02	PAS	NJDEP 15001	11/4/2021	7:01	SM 3113 B	11/5/2021	11:44	14.5	2.00	1	N	
HMS-01-H203-WC-P	N	P21-12151-03	PAS	NJDEP 15001	11/4/2021	7:04	SM 3113 B	11/5/2021	12:00	3.17	2.00	1	N	
HMS-01-H206-WC-P	N	P21-12151-04	PAS	NJDEP 15001	11/4/2021	7:05	SM 3113 B	11/5/2021	14:05	53.9	10.0	5	N	
HMS-01-205-TL1-P	N	P21-12151-05	PAS	NJDEP 15001	11/4/2021	7:06	SM 3113 B	11/5/2021	12:07	10.1	2.00	1	N	
HMS-01-205-TL2-P	N	P21-12151-06	PAS	NJDEP 15001	11/4/2021	7:08	SM 3113 B	11/5/2021	14:09	24.2	4.00	2	N	
HMS-01-208-CF1-P	N	P21-12151-07	PAS	NJDEP 15001	11/4/2021	7:09	SM 3113 B	11/5/2021	14:12	32.3	6.00	3	N	
HMS-01-208-CF2-P	N	P21-12151-08	PAS	NJDEP 15001	11/4/2021	7:10	SM 3113 B	11/5/2021	14:16	110	20.0	10	N	
HMS-01-208-CF3-P	N	P21-12151-09	PAS	NJDEP 15001	11/4/2021	7:11	SM 3113 B	11/5/2021	14:19	83.9	20.0	10	N	
HMS-01-207-NS-P	N	P21-12151-10	PAS	NJDEP 15001	11/4/2021	7:13	SM 3113 B	11/5/2021	14:23	150	50.0	25	N	
HMS-01-303-WC-P	N	P21-12151-11	PAS	NJDEP 15001	11/4/2021	7:18	SM 3113 B	11/5/2021	12:56	0.570	2.00	1	N	ND
HMS-01-306-WC-P	N	P21-12151-12	PAS	NJDEP 15001	11/4/2021	7:20	SM 3113 B	11/5/2021	12:59	1.87	2.00	1	N	J



QUALITY ASSURANCE PROJECT PLAN  
HIGH BRIDGE SCHOOL DISTRICT  
NOVEMBER 2021



PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result \* Federal Action Level

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)primary / (F)lush

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT = Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT = Bottle Filler
- HB = Hose Bib