

SAMPLENAME	LABSAMPID	MATRIX	SAMPDATE	METHODCODE	ANALYTE	RESULT	RL	UNITS
HMS- Field Blank	AC35692-01	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-H Gym-WC-P	AC35692-02	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	1.07	1.00	µg/L
HMS-1-H Gym-BT-P	AC35692-03	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-1-H Rm 201-WC-P	AC35692-04	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-1-H Rm 201-BT-P	AC35692-05	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-1-Nur-NS1-P	AC35692-06	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	9.56	1.00	µg/L
HMS-1-Nur-NS2-P	AC35692-07	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	15.3	1.00	µg/L
HMS-1-Rm 208-CF 1-P	AC35692-08	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	29.6	1.00	µg/L
HMS-1-Rm 208-CF 2-P	AC35692-09	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	37.3	1.00	µg/L
HMS-1-Rm 208-CF 3-P	AC35692-10	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	84.5	1.00	µg/L
HMS-1-Rm 207-CF-P	AC35692-11	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	25.9	1.00	µg/L
HMS-2-H RM 303-WC-P	AC35692-12	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-2-H RM 303-BT-P	AC35692-13	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-1-H RM 103-WC-P	AC35692-14	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-1-H RM 103-BT-P	AC35692-15	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-1-RM 103-TF-P	AC35692-16	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	8.25	1.00	µg/L
HMS-1-RM 101-CF1-P	AC35692-17	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	10.9	1.00	µg/L
HMS-1-RM 101-CF2-P	AC35692-18	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	19.4	1.00	µg/L
HMS-1-RM 109-CF-P	AC35692-19	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	19.5	1.00	µg/L
HMS-1-CAFE-WC-P	AC35692-20	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-1-CAFE-BT-P	AC35692-21	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
HMS-1-RM 113-TF-P	AC35692-22	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	23.2	1.00	µg/L
HMS-1-KITCHEN-FP-P	AC35692-23	Drinking Water	10/30/2024	01-Metals 200.8 Lead (Pb)	Lead	27.8	1.00	µg/L

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

IM = Ice Machine

KC = Kitchen Outlet, Cold

KT= Kettle

SB = Sink/Bubbler Combination

TF/TS = Teachers Faucet

WC = Water Cooler

BT = Bottle Filler

HB = Hose Bib

ST = Steamer

SP = Sprayer